



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010305641303

**NAME AND ADDRESS OF THE APPLICANT**

Danfoss A/S  
Nordborgvej 81, DK-6430 Nordborg Denmark

**NAME AND ADDRESS OF THE MANUFACTURER**

Danfoss A/S  
Nordborgvej 81, DK-6430 Nordborg Denmark

**NAME AND LOCATION OF THE FACTORY**

Danfoss Sp.z.o.o.  
UL.Chrzanowska 5, 05-825 Grodzisk Mazowiecki, Poland

**PRODUCT NAME,MODEL AND SPECIFICATION**

Pressure or Temperature Switch

KP...; Ui:400V; Uimp:4kV; Ith:16A ; KP ( Gold contact ) : AC-15:Ue/Ie:230V/6A,400V/4A; DC-13:Ue/Ie:220V/50mA; KP  
( Silver contact ) :AC-15:Ue/Ie:230V/16A,400V/10A; DC-13:Ue/Ie:220V/50mA; KPI :AC-15:Ue/Ie:230V/6A,400V/2.5A;  
DC-13:Ue/Ie:220V/50mA; IP55/IP44; See the Appendix

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Oct.15,2024

**Valid until:** Oct.14,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to  
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010305641303

Appendix: Page 1 of 1

型号解释 Type description:

KP	x	x
A	B	C

A: 字母表示产品系列名称

KP:主要用于介质为气体和空气的场合

KPI: 除了介质为气体和空气的场合，可用于介质为液体的场合

B: 代表 1-100 的数字，表示不同的控制压力或温度范围，其中数字 1-59 是压力开关，60-100 是温度开关

C: 代表如下字母或字母组合或空白，表示产品其他附加信息

A- 可使用 R717(NH<sub>3</sub>)制冷剂

W- 自动复位

B- 手动外部复位

S- 手动内部复位

空白 - 无

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



# 中国国家强制性产品认证证书

证书编号：2024010305641303

认证委托人名称及地址  
丹佛斯 A/S 公司  
诺顿勃格 81, DK-6430, 丹麦

生产者名称及地址  
丹佛斯 A/S 公司  
诺顿勃格 81, DK-6430, 丹麦

生产企业名称及地址  
Danfoss Sp. z. o. o.  
UL. 克莱诺斯卡 5 号, 05-825 格劳德里斯克 麦斯维克, 波兰 05-825

产品名称和系列、型号、规格  
压力或温度开关  
KP...; Ui:400V; Uimp:4kV; Ith:16A; KP (金触头): AC-15:Ue/Ie:230V/6A,400V/4A;  
DC-13:Ue/Ie:220V/50mA; KP (银触头): AC-15:Ue/Ie:230V/16A,400V/10A;  
DC-13:Ue/Ie:220V/50mA; KPI: AC-15:Ue/Ie:230V/6A,400V/2.5A; DC-13:Ue/Ie:220V/50mA;  
IP55/IP44; 型号解释见附页

产品标准和技术要求  
GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2024 年 10 月 15 日 有效期至: 2029 年 10 月 14 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,  
也可在认监委网站 ([www.cnca.gov.cn](http://www.cnca.gov.cn)) 查询。



签发:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号：2024010305641303

证书附页：第 1 页 共 1 页

型号解释 Type description:

KP	x	x
A	B	C

A: 字母表示产品系列名称

KP: 主要用于介质为气体和空气的场合

KPI: 除了介质为气体和空气的场合，可用于介质为液体的场合

B: 代表 1-100 的数字，表示不同的控制压力或温度范围，其中数字 1-59 是压力开关，60-100 是温度开关

C: 代表如下字母或字母组合或空白，表示产品其他附加信息

A- 可使用 R717(NH<sub>3</sub>)制冷剂

W- 自动复位

B- 手动外部复位

S- 手动内部复位

空白 - 无

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司