










Approvals Document - North America Zone Rosemount™ 8750W Magnetic Flowmeter



Rosemount™ 8750W Magnetic Flowmeter Platform

Order Code	8750W Magnetic Flowmeter Platform Rating	Region	Agency	Certification Number
-	Ordinary Locations*	USA, Canada, EU, EEU**	CSA, EAC	80102916
Z1	ATEX Non-Sparking or Increased Safety and Dust for Non-Flammable Fluids	EU	DEKRA	DEKRA 15ATEX0003 X
ND	ATEX Dust	EU	DEKRA	DEKRA 15ATEX0003 X
Z2	INMETRO Increased Safety and Dust for Non-Flammable Fluids	Brazil	DNV - INMETRO	DNV 18.0082 X DNV 23.0087 X DNV 23.0088 X
Z3	NEPSI Non-Sparking and Dust for Non-Flammable Fluids	China	NEPSI	GYJ20.1283X
Z5	DIP (Dust-Ignitionproof) Class II and III, Div 1. Non-Incendive, Class I Div 2 for Non-Flammable Fluids	USA	CSA	80102916
Z6	DIP (Dust-Ignitionproof) Class II and III, Div 1. Non-Incendive, Class I Div 2 for Non-Flammable Fluids	USA & Canada	CSA	80102916
ZC	North America Approvals, Class I Zone 2, Class II Zone 22	USA & Canada	CSA	80102916
Z7	IECEX Non-Sparking or Increased Safety and Dust for Non-Flammable Fluids	Global	DEKRA	IECEX DEK 15.0001X
NF	IECEX Dust	Global	DEKRA	IECEX DEK 15.0001X
Z9	KTL Non-Sparking and Dust for Non-Flammable Fluids	Korea	KTL	***
ZW	PESO Non-Sparking or Increased Safety	India	PESO	A/P/HQ/MH/104/7162: P538675/1
*Complies with only the local country Product safety, Electromagnetic, Pressure and other applicable regulations. Cannot be used in a classified or zoned hazardous location environment.				
** EEU – Eurasian Economic Union				
*** Future				

Approval Markings and Logos

Symbol	Marking or Symbol Name	Region	Meaning of Marking or Symbol
	CE	European Union	Compliance with all applicable European Union Directives.
	ATEX	European Union	Compliance with Equipment and Protective systems intended for use in Potentially Explosive Atmospheres directive (ATEX) (2014/34/EU)
	RCM	Australia and New Zealand	Compliance with Australian/New Zealand applicable electromagnetic compatibility and electrical safety standards
	CSA	US = United States C = Canada	Indicates that the product was tested and has met the applicable certification requirements for the noted countries.
	Eurasian Conformity (EAC)	EEU – Eurasian Economic Union	Compliance with all applicable technical regulations of the EAC Eurasian Economic Union
	EEU Pattern Approval Certificate	EEU – Eurasian Economic Union	Indicates compliance of measuring instruments with the approved metrological and technical characteristics.
	DNV - INMETRO	Brazil	Compliance with all applicable technical regulations of Brazil.
	NEPSI	China	Compliance with all applicable technical regulations of China.
	KTL	Korea	Compliance with all applicable technical regulations of Korea.

Ordinary Location labels will be marked with CE, RCM, CSA and EAC logos.

European Directive Information

The most recent revision of the EU Declaration of Conformity can be found at www.emerson.com.

Certifications

Canadian Standards Association (CSA)

Ordinary Location Certification - CLASS 2252 06 (Canada) and CLASS 2252 86 (US)

The transmitter and flowtube have been examined and tested to determine that the design meets basic electrical, mechanical, and fire protection requirements by CSA, a nationally recognized testing laboratory (NRTL) as accredited by the Federal Occupational Safety and Health Administration (OSHA).

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - To Canadian Requirements.

Z6, Z5	Class I, Division 2, Groups A, B, C and D; T4 (Non-Incendive)
ZC	Ex nA [ic] IIC T4 Gc (Transmitter - DC Powered Only)
ZC	Ex ec [ic] IIC T4 Gc (Transmitter - DC Powered Only)
ZC	Ex nA ic [ic] IIC T4 Gc (8750WDMW Transmitter - DC Powered Only)
ZC	Ex ec ic [ic] IIC T4 Gc (8750WDMWTransmitter - DC Powered Only)
ZC	Ex nA ic IIC T5...T4 Gc (Flow Tube)
ZC	Ex ec ic IIC T5...T4 Gc (Flow Tube)
Z6, Z5	Class II, Division 1, Groups E, F and G, T5; Class III (Dust Ignition Proof)
ZC	Ex tc IIIC T80 °C...T130 °C Dc (Transmitter and Flow Tube)
ZC	Ex tc IIIC T80 °C Dc (8750WDMW Transmitter)
ZC	Ex tc [ic] IIIC T80 °C...T130°C Dc (8750WDMT or WDMR Transmitter)
ZC	Ex tc [ic] IIIC T80 °C Dc (8750WDMW Transmitter)

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -To US Requirements

Z6, Z5	Class I, Division 2, Groups A, B, C and D; T4 (Non-Incendive)
ZC	Class I, Zone 2, AEx nA [ic] IIC T4 Gc (Transmitter - DC Powered Only)
ZC	Class I, Zone 2, AEx ec [ic] IIC T4 Gc (Transmitter - DC Powered Only)
ZC	Class I, Zone 2, AEx nA ic [ic] IIC T4 Gc (8750WDMW Transmitter - DC Powered Only)
ZC	Class I, Zone 2, AEx ec ic [ic] IIC T4 Gc (8750WDMWTransmitter - DC Powered Only)
ZC	Class I, Zone 2, AEx nA ic IIC T5...T4 Gc (Flow Tube)
ZC	Class I, Zone 2, AEx ec ic IIC T5...T4 Gc (Flow Tube)
Z6, Z5	Class II, Division 1, Groups E, F and G, T5; Class III (Dust Ignition Proof)
ZC	Class II, Zone 22, AEx tc IIIC T80°C... 130°C Dc (Transmitter and Flow Tube)
ZC	Class II, Zone 22, AEx tc IIIC T80 °C Dc (8750WDMW Transmitter)
ZC	Class II, Zone 22, AEx tc [ic] IIIC T80 °C...T130°C Dc (8750WDMT or WDMR Transmitter)
ZC	Class II, Zone 22, AEx tc [ic] IIIC T80 °C Dc (8750WDMW Transmitter)

8750W Magnetic Flowtube and Transmitter

Z6, Z5 All Flowtubes and Integral or Remote Mount Transmitters (Transmitter mount codes WDMT or WDMR)

Non-Incendive for Class I, Division 2, Groups ABCD: T4

Dust-Ignition Proof for Class II/III, Division 1, Groups EFG: T5

ZC Class I, Zone 2 Non-Sparking or Increased Safety with Intrinsic Safety

Class II, Zone 22 Protection by Enclosure

-29°C ≤ Ta ≤ 60°C

Enclosure Type 4X, IP66/68 (IP68 flowtube only with Remote mount transmitter)

Install per drawing 8750W-1051

8750W Magnetic Flowtube and Transmitter

Z6, Z5 All Flowtubes and Wall Mount Transmitter (Transmitter mount code WDMW)

Non-Incendive for Class I, Division 2, Groups ABCD: T4

Dust-Ignition Proof for Class II/III, Division 1, Groups EFG: T4

ZC Class I, Zone 2 Non-Sparking or Increased Safety with Intrinsic Safety

Class II, Zone 22 Protection by Enclosure

$-29^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$

Enclosure Type 4X, IP66/68/69K (IP68 flowtube only; IP69K Transmitter mount code WDMW)

Install per drawing 8750W-1051

Special Conditions of Safe Use for Class/Division

1. Flow tube to be used only in a non-flammable process.

Special Conditions for Safe Use (X) for Class Zone:

1. When "Special Paint Systems" are applied, instructions for safe use regarding potential electrostatic charging hazard have to be followed.
2. Conduit entries must be installed to maintain the enclosure ingress rating of IP66 (Transmitter and Flow Tube), IP68 (Flow Tube) or IP69K (Flow Tube or 8750W...W transmitter) as applicable.
3. Terminals for the output signals of the Magnetic Flow Transmitters, cannot withstand the 500 V isolation test between signal and ground, due to integral transient protection. This must be taken into account upon installation.
4. When utilizing the keypad of Magnetic Flow Transmitter Model 8750W...W, instructions for safe use regarding potential electrostatic charging hazard have to be followed.

Rosemount 8750W Magnetic Flowmeter Platform - IECEx & ATEX Approvals

1. Equipment Markings – See section VI in the tables on the following pages.
 - a. Type Examination Certificate (ATEX): DEKRA 15ATEX0003 X and Annex 1
 - b. Certificate of Conformity (IECEX): IECEX DEK 15.0001X and Annex 1
2. Required Documentation:
 - a. 8750W-2052 Installation Drawing Model 8750W ATEX/IECEX Hazardous (Ex) Locations
3. Referenced Documentation:
 - a. 00825-0X00-4444.pdf, Transmitter Quick Installation Guide (Where X = Communications Protocol Code)
 - b. 00825-0300-4750.pdf, Sensor Quick Installation Guide
4. The Required and Referenced Documents listed above address the following items:
 - a. Instructions for safety i.e.
 - i. Putting into service
 - ii. Use
 - iii. Assembling and dismantling
 - iv. Maintenance, overhaul and repair
 - v. Installation
 - vi. Adjustment
 - b. Where necessary, training instructions
 - c. Details which allow a decision to be made as to whether the equipment can be used safely in the intended area under the expected operating conditions
 - d. Electrical parameters, maximum surface temperatures and other limit values
 - i. Electrical –
 1. See document 8750W-2052

Rosemount 8750W Flow Transmitter	
<i>Power input</i>	90 - 250VAC, 0.45A, 40VA 12 - 42VDC, 1.2A, 15W
<i>Pulsed circuit</i>	<i>Internally powered (Active): Outputs up to 12VDC, 12.1mA, 73mW</i> <i>Externally powered (Passive): Input up to 28VDC, 100mA, 1W</i>
<i>4-20mA output circuit</i>	<i>Internally Powered (Active): Outputs up to 25mA, 24VDC, 600mW</i> <i>Externally Powered (Passive): Input up to 25mA, 30VDC, 750mW</i>
<i>MODBUS</i>	<i>Internally Powered (Active): Outputs up to 100mA, 3.3VDC, 100mW</i>
<i>Fieldbus</i>	<i>Externally Powered (Passive): 9-32VDC,</i>
<i>Profibus</i>	<i>Externally Powered (Passive): 9-32VDC,</i>
<i>Ethernet/IP</i>	IEEE802.3 (AC Power Input; models 8750WDMT or 8750WDMR)
<i>Um</i>	250V
<i>Coil excitation output</i>	500mA, 40V max, 9W max
Rosemount 8750W Flowtube⁽¹⁾	
<i>Coil excitation input</i>	500mA, 40V max, 20W max
<i>Electrode circuit</i>	5V, 200uA, 1mW

(1) Provided by the transmitter

- e. Special Conditions for Safe Use (X):
 - i. Terminals for the output signals of the Magnetic Flow Transmitters, cannot withstand the 500 V isolation test between signal and ground, due to integral transient protection. This must be taken into account upon installation.
 - ii. When utilizing the keypad of Magnetic Flow Transmitter Model 8750W...W, instructions for safe use regarding potential electrostatic charging hazard have to be followed.
 - iii. Models marked with ESD warning label, do not rub surface with a dry cloth or clean with solvents to avoid electrostatic charge build-up.
 - iv. Conduit entries must be installed to maintain the enclosure ingress rating of IP66 (Transmitter and Flow Tube), IP68 (Flow Tube) or IP69K (Flow Tube or 8750W...W transmitter) as applicable.
- f. Where necessary, the essential characteristics of tools which may be fitted to the equipment
 - i. No proprietary tools required.
- g. List of the standards, including the issue date, with which the equipment is declared to comply:
 - i. ATEX - EN IEC 60079-0 : 2018 , EN 60079-7: 2015+A1:2018 (Ed 5.1), EN 60079-11 : 2012, EN 60079-15 : 2010, EN 60079-31 : 2014
 - ii. IECEx - IEC 60079-0: 2017, IEC 60079-7: 2015+A1: 2017 (Ed 5.1), IEC 60079-11: 2011, IEC 60079-15: 2017, IEC 60079-31: 2022
- h. Supply wire requirements;
Use 10 - 18 AWG wire rated for the proper temperature of the application. For wire 10 - 14 AWG use lugs or other appropriate connectors. For connections in ambient temperatures above 122°F (50 °C), use a wire rated for 194 °F (90 °C).
- i. Contact address; Emerson - Rosemount, Micro Motion Inc
12001 Technology Drive
Eden Prairie, MN 55344, United States of America

Nomenclature Magnetic Flow Meter System Model 8750W and electrical data

8750W ... R 1 A 2 ... F 005 ... Z1 ... M4 ... AX ... V1 ... R50
 I II III IV V VI VII VIII IX X XI XII

Designation	Explanation	Value	Explanation
I	Model	8750W	Flow Meter System Model 8750W
II	Transmitter Mount	R T W	Remote Mount Integral Mount Wall Mount
III	Transmitter Power Supply	1 2	AC (90 - 250 Vac, 50 / 60 Hz), not for Ex nA or Ex ec DC (12 - 42 Vdc)
IV	Transmitter Outputs	A M F P E 0	Non-I.S.: 4 - 20 mA with digital HART Protocol & Scalable Pulse Output Non-I.S.: Modbus RS-485 I.S.: Foundation Fieldbus / FISCO Intrinsically Safe & Intrinsically Safe Scalable Pulse Output I.S.: Profibus & Intrinsically Safe Scalable Pulse Output Non-I.S. Ethernet/IP and Pulse Output (Safety Approvals ND, NF (Ex tc)) Spare Flow Tube, no Transmitter
V	Conduit Entries	1 2 4 5	½-14 NPT female CM20, M20 female ½-14 NPT female, 8750W...R / T only CM20, M20 female, 8750W...R / T only
VI	Electrode Type	A, B, E, F 0	Seal of electrodes comply with IEC 61010-1. Spare Transmitter, No Flow Tube
VII	Line Size	005 to 480 000	½" NPS (15 mm) to 48" NPS (1200 mm) Spare Transmitter, no Flow Tube

Continued on next page

Nomenclature Magnetic Flow Meter System Model 8750W and electrical data (continued)

8750W ... R 1 A 2 ... F 005 ... Z1 ... M4 ... AX ... V1 ... R50
I II III IV V VI VII VIII IX X XI XII

Designation	Explanation	Value	Explanation
VIII	Safety Approvals	Z1 ATEX	Transmitter Models 8750W...R and 8750W...T: Ⓜ II 3 G Ex nA [ic] IIC T4 Gc * Ⓜ II 3 G Ex ec [ic] IIC T4 Gc * Ⓜ II 3 D Ex tc IIIC T80 °C...T130 °C Dc ** Transmitter Models 8750W...R and 8750W...T: Ⓜ II 3 G Ex nA [ic] IIC T4 Gc * Ⓜ II 3 G Ex ec [ic] IIC T4 Gc * Ⓜ II 3 D Ex tc [ic] IIIC T80 °C...T130 °C Dc **,*** Transmitter Model 8750W...W: Ⓜ II 3 G Ex nA ic [ic] IIC T4 Gc * Ⓜ II 3 G Ex ec ic [ic] IIC T4 Gc * Ⓜ II 3 D Ex tc IIIC T80 °C Dc ** Transmitter Model 8750W...W: Ⓜ II 3 G Ex nA ic [ic] IIC T4 Gc * Ⓜ II 3 G Ex ec ic [ic] IIC T4 Gc * Ⓜ II 3 D Ex tc [ic] IIIC T80 °C Dc **,*** Flow Tube: Ⓜ II 3 G Ex nA ic IIC T5...T4 Gc Ⓜ II 3 G Ex ec ic IIC T5...T4 Gc Ⓜ II 3 D Ex tc IIIC T80 °C...T130 °C Dc
		Z7 / Z9 IECEX	Transmitter Models 8750W...R and 8750W...T: Ex nA [ic] IIC T4 Gc * Ex ec [ic] IIC T4 Gc * Ex tc IIIC T80 °C...T130 °C Dc ** Transmitter Models 8750W...R and 8750W...T: Ex nA [ic] IIC T4 Gc * Ex ec [ic] IIC T4 Gc * Ex tc [ic] IIIC T80 °C...T130 °C Dc **,*** Transmitter Model 8750W...W: Ex nA ic [ic] IIC T4 Gc * Ex ec ic [ic] IIC T4 Gc * Ex tc IIIC T80 °C Dc ** Transmitter Model 8750W...W: Ex nA ic [ic] IIC T4 Gc * Ex ec ic [ic] IIC T4 Gc * Ex tc [ic] IIIC T80 °C Dc **,*** Flow Tube: Ex nA ic IIC T5...T4 Gc Ex ec ic IIC T5...T4 Gc Ex tc IIIC T80 °C...T130 °C Dc
		ND ATEX	Transmitter Models 8750W...R and 8750W...T + Flow Tube: Ⓜ II 3 D Ex tc IIIC T80 °C...T130 °C Dc ** Ⓜ II (3) G Ex tc [ic] IIIC T80 °C...T130 °C Dc **,*** Transmitter Model 8750W...W: Ⓜ II 3 D Ex tc IIIC T80 °C Dc ** Ⓜ II (3) G Ex tc [ic] IIIC T80 °C Dc **,***
		NF IECEx	Transmitter Models 8750W...R and 8750W...T + Flow Tube: Ex tc IIIC T80 °C...T130 °C Dc ** Ex tc [ic] IIIC T80 °C...T130 °C Dc **,*** Transmitter Model 8750W...W: Ex tc IIIC T80 °C Dc ** Ex tc [ic] IIIC T80 °C Dc **,***
			NOTE: * Model 8750W Transmitter DC Power Supply only ** Model 8750W Transmitter AC and DC Power Supply *** Intrinsically Safe Output (see IV) options F or P

Continued on next page



Nomenclature Magnetic Flow Meter System Model 8750W and electrical data (continued)

8750W ... R 1 A 2 ... F 005 ... Z1 ... M4 ... AX ... V1 ... R50
I II III IV V VI VII VIII IX X XI XII

Designation	Explanation	Value	Explanation
IX	Transmitter Display	-- M4 M5	Without LOI and keypad LOI (+keypad for Transmitter model 8750W...W only) Display
X	Transmitter Discrete Input / Output	AX	Two Discrete Channels (DI/DO 1, DO 2)
XI	Specials Paint	Vx	Special Paint Systems *** NOTE: *** Subject to special conditions for safe use.
XII	Remote Cable	Rxx ****	Standard Temperature Component NOTE: **** Length = XX x 10ft., max 500 ft.



EU Declaration of Conformity



We,

Emerson – Rosemount, Micro Motion Inc
 12001 Technology Drive
 Eden Prairie, MN 55344
 USA

declare under our sole responsibility that the product: **Rosemount™ 8750W Magnetic Flowmeter System**

Authorized Representative in Europe:
 Emerson S.R.L., company No. J12/88/2006,
 Emerson 4 street, Parcul Industrial
 Tetarom II, Cluj-Napoca 400638, Romania

Regulatory Compliance Shared Services Department
 Email: europaeproductcompliance@emerson.com
 Phone: +40 374 132 035

to which this declaration relates, is in conformity with the provisions of the European Union Directives, including the latest amendments.


 (signature and date of issue)

2/7/2025

Mark Fleigle
 (name)

Vice President, Engineering
 (function)

Eden Prairie, MN USA
 (place of issue)

PED Notified Body
DNV Business Assurance Italia S.r.l.
 [Notified Body Number: 0496]
 Via Energy Park, 14, N-20871
 Vimercate (MB), Italy



EU Declaration of Conformity



EMC Directive (2014/30/EU)

Harmonized Standards: EN 61326-1:2013

Low Voltage Directive (2014/35/EU)

All Models:

Harmonized Standards: EN 61010-1:2010

PED Directive (2014/68/EU)

Equipment without the 'PD' option is NOT PED compliant and cannot be used in the EU without further assessment unless the installation is exempt under Article 1, paragraph 2 of the PED Directive 2014/68/EU.

Model 8750W Magnetic Flowmeter System Sensor with option 'PD', in line sizes 1.5-inch (DN40) to 24-inch (DN600).

DNV QS Certificate of Assessment

Certificate No. 10000497900-PA-ACCREDIA-USA

Module H Conformity Assessment - ASME B31.3: 2020

Model 8750W Magnetic Flowmeter System Sensor with option 'PD', in line sizes 0.5-inch (DN15) to 1.0-inch (DN25).

Sound Engineering Practice - ASME B31.3: 2020

ATEX Directive (2014/34/EU)

8750W Magnetic Flowmeter System

DEKRA 15ATEX0003 X - CERTIFICATE

Equipment Marking Summary:

II 3 G	Ex nA [ic] IIC T4 Gc:
II 3 G	Ex ec [ic] IIC T4 Gc
II 3 G	Ex nA ic IIC T5...T4 Gc
II 3 G	Ex ec ic IIC T5...T4 Gc
II 3 G	Ex nA ic [ic] IIC T4 Gc:
II 3 G	Ex ec ic [ic] IIC T4 Gc
II 3 D	Ex tc IIIC T 80°C Dc
II 3 D	Ex tc IIIC T 80°C...T 130°C Dc
II 3 D	Ex tc [ic] IIIC T 80°C Dc
II 3 D	Ex tc [ic] IIIC T 80°C...T 130°C Dc

Harmonized Standards:

EN IEC 60079-0: 2018	EN 60079-7: 2015 + A1: 2018
EN 60079-11: 2012	EN 60079-15: 2010
EN 60079-31: 2014	

Translations of this document are available upon request.

PAGE	TITLE
2	GAS ENVIRONMENT - EPL Gc SENSOR WITH ALLOWED INTEGRAL MOUNT EPL Gc TRANSMITTERS
3	GAS ENVIRONMENT - EPL Gc SENSOR WITH ALLOWED REMOTE MOUNT EPL Gc TRANSMITTERS
4	DUST ENVIRONMENT - EPL Dc SENSOR WITH ALLOWED INTEGRAL MOUNT EPL Dc TRANSMITTERS
5	DUST ENVIRONMENT - EPL Dc SENSOR WITH ALLOWED REMOTE MOUNT EPL Dc TRANSMITTERS
6	GAS AND DUST ENVIRONMENT - EPL Gc AND EPL Dc - SENSOR TEMPERATURE CODE VS. PROCESS TEMPERATURE AND INGRESS PROTECTION RATINGS
7	GAS ENVIRONMENT - EPL Gc COIL AND ELECTRODE CIRCUIT WIRING
8	DUST ENVIRONMENT - EPL Dc COIL AND ELECTRODE CIRCUIT WIRING
9	GAS AND DUST ENVIRONMENT - OUTPUT WIRING
10	GAS AND DUST ENVIRONMENT - INTRINSICALLY SAFE ENTITY CONCEPTS
11	GAS AND DUST ENVIRONMENT - FISCO CONCEPT

⚠ WARNING: EXPLOSION HAZARD - PRODUCT INSTALLATION SHALL COMPLY WITH INFORMATION AS STATED IN THIS DOCUMENT.

- 1.** WIRING METHOD SUITABLE FOR APPROPRIATE ZONE AND PROTECTION TYPE.
- 2.** TRANSMITTER MUST NOT BE CONNECTED TO EQUIPMENT GENERATING MORE THAN 250V.
- 3.** COMPONENTS REQUIRED TO HAVE HAZARDOUS (Ex) LOCATION APPROVAL MUST BE APPROVED FOR THE GAS GROUP APPROPRIATE TO AREA CLASSIFICATION.

4. FOR ALL INSTALLATIONS MAXIMUM TERMINAL TIGHTENING TORQUE IS 10.6 IN LBS.

5. THE ELECTRODE CIRCUIT AND WIRING MUST BE INSTALLED AS INTRINSICALLY SAFE WHEN THE FLOWTUBE IS INSTALLED IN A HAZARDOUS (Ex) AREA WITH AN EQUIPMENT PROTECTION LEVEL (EPL) OF Gc.

6. NO REVISION TO THIS DRAWING WITHOUT PRIOR CSA APPROVAL.

7. USA-INSTALLATION SHALL BE IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE (NEC), NFPA-70, AND ANSI/ISA-RP1206.01. CANADA-INSTALLATION SHALL BE IN ACCORDANCE WITH THE CANADIAN ELECTRICAL CODE (CEC) PART I (C22.1).

- 8.**
 - WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT WHILE CIRCUIT IS LIVE UNLESS AREA IS KNOWN TO BE NON-HAZARDOUS.
 - AVERTISSEMENT - RISQUE D'EXPLOSION. NE PAS DEBRANCHER TANT QUE LE CIRCUIT EST SOUS TENSION, A MOINS QU'IL NE S'AGISSE D'UN EMPLACEMENT NON DANGEREUX.
 - WARNING - AFTER DE-ENERGIZING, DELAY 10 MINUTES BEFORE OPENING.
 - AVERTISSEMENT - APRÈS MISE HORS TENSION, ATTENDRE 10 MINUTES AVANT L'OUVERTURE.
 - WARNING - POTENTIAL ELECTROSTATIC CHARGING HAZARD - SEE INSTRUCTIONS.
 - AVERTISSEMENT - DANGER POTENTIEL DE CHARGES ELECTROSTATIQUES - VOIR INSTRUCTIONS

9. THE TRANSMITTER IS NOT CAPABLE OF PASSING THE 500V ISOLATION TEST ON TERMINALS DUE TO INTEGRAL TRANSIENT PROTECTION. THIS MUST BE TAKEN INTO ACCOUNT UPON INSTALLATION.

10. THE ROSEMOUNT CABLING KITS, FOR INTRINSICALLY SAFE ELECTRODES, INCLUDE A CERTIFICATE OF CONFORMITY (COC) FROM THE MANUFACTURER FOR CAPACITANCE PER FOOT & INDUCTANCE PER FOOT. THESE PARAMETERS ARE ONLY REQUIRED FOR THE ENTITY CONCEPT METHOD OF INSTALLATION.

11. THE INTRINSICALLY SAFE ANALOG AND DIGITAL OUTPUTS MUST USE TWISTED PAIR WITH AN INDIVIDUAL SHIELD FOR THE PAIR. IT IS ALSO RECOMMENDED TO USE SHIELDED TWISTED PAIR FOR THE PULSE OUTPUT.

12. SEAL APPROVED FOR USE IN APPROPRIATE ZONE AND GAS GROUP.

13. TRANSMITTER OUTPUTS ARE CONSIDERED INTRINSICALLY SAFE WHEN INSTALLED IN ACCORDANCE TO INTRINSICALLY SAFE CONCEPTS AND INSTALLATION REQUIREMENTS WITHIN THIS DOCUMENT.

14. THE TEMPORARY SHIPPING PLUGS SHALL BE REMOVED AND REPLACED WITH APPROPRIATELY RATED PLUGS/CONNECTIONS. COVERS MUST BE CLOSED TO MAINTAIN INGRESS PROTECTION RATINGS.

NOTES:


REVISION TABLE			
REVISION	ECO NO.	APP'D	DATE
AE	1374541	EAB	10/7/24
DESCRIPTION			
ADD FLAG NOTE 14 FOR REPLACING SHIPPING PLUGS WITH RATED CONDUIT PLUGS UPDATE TEMPS FOR 8750WDMR DUST RATINGS. UPDATE IP RATINGS			

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.	SURFACE FINISH UNLESS OTHERWISE SPECIFIED ∇	125°	3RD ANGLE		SIZE C	SCALE -	REV AE
TITLE ROSEMOUNT INSTALLATION DRAWING 8750W, CSA CANADIAN AND USA ZONE							
DR. J. LAGE 9/16/15 APP'D M. MAYER 9/16/15		DRAWING NO. 8750W-2051		PRODUCT CODE SHEET 1 OF 11			


GAS ENVIRONMENT - EPL Gc SENSOR WITH ALLOWED INTEGRAL MOUNT CONFIGURATIONS

Ex nA OR Ex ec ec SENSOR INTEGRAL MOUNT CONFIGURATIONS

MODEL 8750WD INTEGRAL MOUNT CONFIGURATION WITH SAFETY APPROVAL OPTION 'ZC'



Ex nA ic IIC T5...T4 Gc OR Ex ec ic IIC T5...T4 Gc EPL Gc, FOR USE IN HAZARDOUS (Ex) AREA - ZONE 2 WITH CARBON STEEL HOUSING (-29°C ≤ Ta ≤ 60°C) SEE TABLE 1 FOR PROCESS TEMPERATURE LIMITS AND ALLOWED MOUNTING CONFIGURATIONS TYPE 'n' OR 'e' WITH INTRINSICALLY SAFE ELECTRODES




MODEL 8750WDMT INTEGRAL ZC OPTION

ELECTRODES CONTACT PROCESS

* TYPICAL APPLICATION: CONSULT LOCAL HAZARDOUS AREA (Ex) ZONING FOR PROCESS FLUID CLASSIFICATION.

ALLOWED INTEGRAL MOUNT TRANSMITTER CONFIGURATIONS

MODEL 8750WD INTEGRAL MOUNT CONFIGURATION WITH SAFETY APPROVAL OPTION 'ZC'



Ex nA [ic] IIC T4 Gc - DC POWER ONLY, IN PROTECTION TYPE 'n' Ex ec [ic] IIC T4 Gc - DC POWER ONLY, IN PROTECTION TYPE 'e' EPL Gc, FOR USE IN HAZARDOUS (Ex) AREA - ZONE 2 SEE TABLE 1 FOR PROCESS TEMPERATURE LIMITS AND ALLOWED MOUNTING CONFIGURATIONS

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.	SURFACE FINISH UNLESS OTHERWISE SPECIFIED	125	3RD ANGLE		SIZE	C	SCALE	-	REV	AE
	DRAWING NO. 8750W-2051									
EMERSON										
ROSEMOUNT										
TITLE INSTALLATION DRAWING 8750W, CSA CANADIAN AND USA ZONE										
DR. J. LAGE 9/16/15 DRAWING NO. 8750W-2051										
APPD. M. MAYER 9/16/15 PRODUCT CODE										
DO NOT SCALE PRINT CAD MAINTAINED (PROJ) SHEET 2 OF 11										


UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.

-DEC TOLERANCES-	
X ± .1	[2.5]
.XX ± .02	[0.5]
.XXX ± .010	[0.25]
FRACTIONS ± 1/32	ANGLES ± 2°


GAS ENVIRONMENT - EPL Gc SENSOR WITH ALLOWED REMOTE MOUNT EPL Gc TRANSMITTERS

Ex nA OR Ex ec SENSOR REMOTE MOUNT CONFIGURATIONS

MODEL 8750WD REMOTE MOUNT SENSOR CONFIGURATION
WITH SAFETY APPROVAL OPTION 'ZC'




Ex nA ic IIC T5...T4 Gc OR Ex ec ic IIC T5...T4 Gc
EPL Gc. FOR USE IN HAZARDOUS (Ex) AREA - ZONE 2
WITH CARBON STEEL HOUSING (-29°C ≤ Ta ≤ 60°C)
SEE TABLE 1 FOR PROCESS TEMPERATURE LIMITS AND
ALLOWED MOUNTING CONFIGURATIONS
TYPE 'n' OR 'e' WITH INTRINSICALLY SAFE ELECTRODES




ALLOWED REMOTE MOUNT TRANSMITTER CONFIGURATIONS

MODEL 8750WD REMOTE FIELD MOUNT CONFIGURATION
WITH SAFETY APPROVAL OPTION 'ZC'




Ex nA [ic] IIC T4 Gc - DC POWER ONLY, IN PROTECTION TYPE 'n'
Ex ec [ic] IIC T4 Gc - DC POWER ONLY, IN PROTECTION TYPE 'e'
EPL Gc. FOR USE IN HAZARDOUS (Ex) AREA - ZONE 2
TEMPERATURE CLASS: EPL Gc: T4 (-40°C ≤ Ta ≤ 60°C)
WITH INTRINSICALLY SAFE ELECTRODE CIRCUIT


MODEL 8750WD REMOTE WALLMOUNT CONFIGURATION
WITH SAFETY APPROVAL OPTION 'ZC'



Ex nA [ic] IIC T4 Gc - DC POWER ONLY, IN PROTECTION TYPE 'n'
Ex ec [ic] IIC T4 Gc - DC POWER ONLY, IN PROTECTION TYPE 'e'
EPL Gc. FOR USE IN HAZARDOUS (Ex) AREA - ZONE 2
TEMPERATURE CLASS: EPL Gc: T4 (-40°C ≤ Ta ≤ 60°C)
WITH INTRINSICALLY SAFE ELECTRODE CIRCUIT



MODEL 8750WDMR
REMOTE MOUNT
ZC OPTION



MODEL 8750WDMW
WALL MOUNT
ZC OPTION

8750W-2051

DRAWING NO.


CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.	SURFACE FINISH UNLESS OTHERWISE SPECIFIED	125	3RD ANGLE	SIZE	C	SCALE	-	REV	AE
UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.	ROSEMOUNT								
-DEC TOLERANCES-	EMERSON								
X ± .1 [2.5]	TITLE								
.XX ± .02 [0.5]	INSTALLATION DRAWING 8750W,								
.XXX ± .010 [0.25]	CSA CANADIAN AND USA ZONE								
FRACTIONS ± 1/32	DR. J. LAGE 9/16/15 DRAWING NO. 8750W-2051								
ANGLES ± 2°	APPD. M. MAYER 9/16/15								
DO NOT SCALE PRINT	CAD MAINTAINED. (PROJ) PRODUCT CODE SHEET 3 OF 11								

* TYPICAL APPLICATION. CONSULT LOCAL HAZARDOUS AREA (Ex) ZONING FOR PROCESS FLUID CLASSIFICATION.


DUST ENVIRONMENT - EPL Dc SENSOR WITH ALLOWED INTEGRAL MOUNT EPL Dc TRANSMITTERS

Ex tc SENSOR INTEGRAL MOUNT CONFIGURATIONS

MODEL 8750WD INTEGRAL MOUNT CONFIGURATION WITH SAFETY APPROVAL OPTION 'ZC'




Ex tc IIIC T80°C...T130°C Dc EPL Dc, FOR USE IN ZONE 22 WITH CARBON STEEL HOUSING (-29°C ≤ Ta ≤ 60°C) SEE TABLE 2 FOR PROCESS TEMPERATURE LIMITS AND ALLOWED MOUNTING CONFIGURATION



ALLOWED INTEGRAL MOUNT TRANSMITTER CONFIGURATIONS

MODEL 8750WD INTEGRAL MOUNT CONFIGURATION WITH SAFETY APPROVAL OPTION 'ZC'



Ex tc IIIC T80°C...T130°C Dc Ex tc [fc] IIIC T80°C...T130°C Dc EPL Dc, FOR USE IN ZONE 22 SEE TABLE 2 FOR TEMPERATURE CLASS AND SPECIFIED MAXIMUM SURFACE TEMPERATURE "T" OF FLOWTUBES ON WHICH THE TRANSMITTER IS MOUNTED


8750W-2051
DRAWING NO.

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.	SURFACE FINISH UNLESS OTHERWISE SPECIFIED	125	3RD ANGLE	SIZE C	SCALE -	REV AE
UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.	EMERSON					
-DEC TOLERANCES- X ± .1 [2.5] .XX ± .02 [0.5] .XXX ± .010 [0.25] FRACTIONS ± 1/32 ANGLES ± 2'	ROSEMOUNT					
TITLE INSTALLATION DRAWING 8750W, CSA CANADIAN AND USA ZONE						
DR. J. LAGE	9/16/15	DRAWING NO.	8750W-2051			
APPD. M. MAYER	9/16/15	PRODUCT CODE	DO NOT SCALE PRINT CAD MAINTAINED. (PROJ)			
DO NOT SCALE PRINT		CAD MAINTAINED. (PROJ)		PRODUCT CODE		SHEET 4 OF 11

DUST ENVIRONMENT - EPL Dc SENSOR WITH ALLOWED REMOTE MOUNT EPL Dc TRANSMITTERS

Ex tc SENSOR REMOTE MOUNT CONFIGURATIONS


MODEL 8750WD REMOTE MOUNT SENSOR CONFIGURATION
WITH SAFETY APPROVAL OPTION 'ZC'



Ex tc IIIC T80°C...T130°C Dc
EPL Dc, FOR USE IN ZONE 22
WITH CARBON STEEL HOUSING (-29°C ≤ Ta ≤ 60°C)
SEE TABLE 2 FOR PROCESS TEMPERATURE LIMITS
AND ALLOWED MOUNTING CONFIGURATION


ALLOWED REMOTE MOUNT TRANSMITTER CONFIGURATIONS

MODEL 8750WD REMOTE MOUNT CONFIGURATION
WITH SAFETY APPROVAL OPTION 'ZC'




Ex tc IIIC T80°C Dc
Ex tc [ic] IIIC T80°C Dc
EPL Dc, FOR USE IN ZONE 22
REMOTE FIELD MOUNT TRANSMITTER MAXIMUM SURFACE
TEMPERATURE T80°C (-40°C ≤ Ta ≤ 60°C)


UP CONFIGURATION




MODEL 8750WD REMOTE WALL MOUNT CONFIGURATION
WITH SAFETY APPROVAL OPTION 'ZC'



Ex tc IIIC T80°C Dc
Ex tc [ic] IIIC T80°C Dc
EPL Dc, FOR USE IN ZONE 22
REMOTE WALL MOUNT TRANSMITTER MAXIMUM SURFACE
TEMPERATURE T80°C (-40°C ≤ Ta ≤ 60°C)



MODEL 8750WDMR
REMOTE MOUNT
ZC OPTION



MODEL 8750WDMW
WALL MOUNT
ZC OPTION

CONFIDENTIAL AND PROPRIETARY
INFORMATION IS CONTAINED HEREIN
AND MUST BE HANDLED ACCORDINGLY.

UNLESS OTHERWISE SPECIFIED
DIMENSIONS IN INCHES (mm). REMOVE
ALL BURRS AND SHARP EDGES.

-DEC TOLERANCES-
X ± .1 [2.5]
.XX ± .02 [0.5]
.XXX ± .010 [0.25]
FRACTIONS ANGLES
± 1/32 ± 2°

SURFACE FINISH UNLESS
OTHERWISE SPECIFIED

125

3RD ANGLE

SIZE

SCALE

REV
AE



ROSEMOUNT

TITLE
INSTALLATION DRAWING 8750W,
CSA CANADIAN AND USA ZONE

DR. J. LAGE 9/16/15 DRAWING NO.

APPD. M. MAYER 9/16/15

DO NOT SCALE PRINT CAD MAINTAINED (PROJ)

PRODUCT CODE

SHEET 5 OF 11

GAS AND DUST ENVIRONMENT - EPL Gc AND EPL Dc - SENSOR TEMPERATURE CODE VS. PROCESS TEMPERATURE AND INGRESS PROTECTION RATINGS

TABLE 1 - 8750W: Ex nA PROTECTION TYPE 'n' OR PROTECTION TYPE Ex ec

LINE SIZE	MAXIMUM PROCESS TEMPERATURE (°C)	T CLASSIFICATION CODE	MOUNTING CONFIGURATION
ALL	60	T4	SENSOR WITH INTEGRAL MOUNT TRANSMITTER
ALL	90	T4	SENSOR WITH INTEGRAL MOUNT TRANSMITTER
ALL	60	T5	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)
ALL	90	T4	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)
ALL	120	T4	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)
ALL	NOT APPLICABLE	T4	REMOTE FIELD MOUNT TRANSMITTER
ALL	NOT APPLICABLE	T4	REMOTE WALLMOUNT TRANSMITTER

TABLE 2 - 8750W: Ex tc PROTECTION TYPE 't'

LINE SIZE	MAXIMUM PROCESS TEMPERATURE (°C)	MAXIMUM SURFACE TEMPERATURE	MOUNTING CONFIGURATION
ALL	60	T 80°C	SENSOR WITH INTEGRAL MOUNT TRANSMITTER
ALL	90	T 100°C	SENSOR WITH INTEGRAL MOUNT TRANSMITTER
ALL	60	T 80°C	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)
ALL	90	T 100°C	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)
ALL	120	T 130°C	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)
ALL	NOT APPLICABLE	T 80°C	REMOTE FIELD MOUNT TRANSMITTER
ALL	NOT APPLICABLE	T 80°C	REMOTE WALLMOUNT TRANSMITTER

TABLE 3 - 8750W: INGRESS PROTECTION AND CORROSION PROTECTION RATINGS

LINE SIZE	IP RATING	NEMA RATING	MOUNTING CONFIGURATION
ALL	IP66	TYPE 4X	SENSOR WITH INTEGRAL MOUNT TRANSMITTER
ALL	IP66	TYPE 4X	REMOTE FIELD MOUNT TRANSMITTER
ALL	IP66, IP69K	TYPE 4X	REMOTE WALLMOUNT TRANSMITTER
ALL	IP66, IP68* or IP69K	TYPE 4X	REMOTE SENSOR WITH REMOTE JUNCTION BOX (RJB)

* IP x8 submergence depth is 10 meters (30 feet) for 48 hours duration

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.

UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.

-DEC TOLERANCES-
X ± .1 [2.5]
XX ± .02 [0.5]
XXX ± .010 [0.25]
FRACTIONS ANGLES
± 1/32 ± 2°



TITLE
INSTALLATION DRAWING 8750W, CSA CANADIAN AND USA ZONE

DR. J. LAGE 9/16/15 DRAWING NO. 8750W-2051
APPD. M. MAYER 9/16/15

ROSEMOUNT


SURFACE FINISH UNLESS OTHERWISE SPECIFIED
3RD ANGLE
SIZE C
SCALE 1:1
REV AE

DRAWING NO. 8750W-2051


GAS ENVIRONMENT- EPL Gc COIL AND ELECTRODE CIRCUIT WIRING

MODEL 8750WD WITH INTRINSICALLY SAFE ELECTRODE CIRCUIT FOR USE WITH SAFETY APPROVAL OPTION ZC

DIVIDER REQUIRED FOR INTRINSIC SAFETY (Ex i)
 COMPONENT CABLES ONLY. SEE TABLE BELOW FOR COMPATIBLE WIRING. SEE INSTALLATION WIRING DRAWING 08732-1504 FOR CABLING DETAILS. (FOR PROCESS TEMPERATURE LIMITS SEE TABLE 1)




8750WDMR/W FLOWTUBE REMOTE JUNCTION BOX




8750WDMR TRANSMITTER REMOTE JUNCTION BOX

MODEL 8750WD WITH INTRINSICALLY SAFE ELECTRODE CIRCUIT FOR USE WITH SAFETY APPROVAL OPTION ZC

DIVIDER REQUIRED FOR INTRINSIC SAFETY (Ex i)
 COMPONENT CABLES ONLY. SEE TABLE BELOW FOR COMPATIBLE WIRING. SEE INSTALLATION WIRING DRAWING 08712-1504 FOR CABLING DETAILS. (FOR PROCESS TEMPERATURE LIMITS SEE TABLE 1)



8750WDMR/W FLOWTUBE REMOTE JUNCTION BOX



8750WDMW TRANSMITTER (LOWER COVER AND SAFETY COVER ARE NOT SHOWN)

SYSTEM APPROVAL FOR INTRINSICALLY SAFE ELECTRODE INSTALLATION

THE MODEL 8750WD MAGNETIC FLOWMETER REFERENCING CONTROL DRAWING 8750W-2051 MAY USE UP TO 500 FEET (150 METERS) OF ROSEMOUNT SUPPLIED ELECTRODE CABLING FOR INTERCONNECTION OF THE DEVICES. THE CORRECT CABLING IS SUPPLIED AS PART OF THE FOLLOWING ROSEMOUNT CABLING KITS:

COIL AND INTRINSICALLY SAFE ELECTRODE COMPONENT CABLES:

ROSEMOUNT PART NO.	UNIT OF MEASURE	TEMPERATURE RANGE	SEE NOTE
08732-0065-0003	FEET	-20° C TO 75° C	10
08732-0065-0004	METERS	-20° C TO 75° C	
08732-0065-1003	FEET	-50° C TO 125° C	
08732-0065-1004	METERS	-50° C TO 125° C	

INDIVIDUAL OR REPLACEMENT INTRINSICALLY SAFE ELECTRODE COMPONENT CABLES:

ROSEMOUNT PART NO.	UNIT OF MEASURE	TEMPERATURE RANGE	SEE NOTE
08732-0061-0003	FEET	-20° C TO 75° C	10
08732-0061-0004	METERS	-20° C TO 75° C	
08732-0061-1003	FEET	-50° C TO 125° C	
08732-0061-1004	METERS	-50° C TO 125° C	

ENTITY CONCEPT FOR INTRINSICALLY SAFE ELECTRODE INSTALLATION

TERMINALS 19, 18, AND 17 CONTAIN TWO CHANNELS OF AN INTRINSICALLY SAFE CIRCUIT WITH A COMMON RETURN. ENTITY PARAMETERS SHOWN BELOW ARE THE SUMMATION OF BOTH CHANNELS.

TRANSMITTER ENTITY PARAMETERS
 MODEL: 8750WDMT, 8750WDMR, AND 8750WDMW
 INTRINSICALLY SAFE ELECTRODE CIRCUIT
 REMOTE JUNCTION BOX TERMINALS 19, 18, 17
 $U_o = 28.56V$
 $I_o = 5.77mA$
 $P_o = 165mW$
 $C_o = 61.7nF$
 $L_o = 1.0H$

FLOW TUBE ENTITY PARAMETERS
 MODEL: 8750WDMxxxxF
 INTRINSICALLY SAFE ELECTRODE CIRCUIT
 REMOTE JUNCTION BOX TERMINALS 19, 18, 17
 $U_i = 30V$
 $I_i = 50mA$
 $P_i = 1.0W$
 $C_i = 1.9nF$
 $L_i = 630\mu H$

THE ENTITY CONCEPT ALLOWS INTERCONNECTION OF ASSOCIATED APPARATUS AND INTRINSICALLY SAFE APPARATUS WHEN THE FOLLOWING IS TRUE:

$U_o \leq U_i$, $I_o \leq I_i$, $P_o \leq P_i$, $C_o \geq C_i + C_{cable}$, $L_o \geq L_i + L_{cable}$
 THE ALLOWED CAPACITANCE, C_o IS SHARED BETWEEN THE CIRCUITS OF TERMINALS 19, 18, AND 17. CABLE CAPACITANCE MUST BE ASSESSED AS TWICE THE MEASURED VALUE PER LENGTH OF CABLE.

EXAMPLE 1: THE HIGHEST MEASURED CAPACITANCE OF A 3 CONDUCTOR, SHIELDED CABLE IS 58pF/ft WHEN MEASURED CONDUCTOR TO CONDUCTOR TIED TO SHIELD.

$C_{cable} = 2 \times 58pF/ft \times \text{FEET OF CABLE}$
 $C_i + C_{cable} < C_o$
 CABLE LENGTH MUST BE UNDER 515 FEET

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.

UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.

-DEC TOLERANCES-	
X ± .1	[2.5]
.XX ± .02	[0.5]
.XXX ± .010	[0.25]
FRACTIONS ± 1/32	ANGLES ± 2°



ROSEMOUNT
 TITLE
 INSTALLATION DRAWING 8750W,
 CSA CANADIAN AND USA ZONE

DR. J. LAGE 9/16/15 DRAWING NO.
 APPD. M. MAYER 9/16/15
 DO NOT SCALE PRINT | CAD MAINTAINED: (PROJ) | PRODUCT CODE | SHEET 7 OF 11

REVISIONS
 SURFACE FINISH UNLESS OTHERWISE SPECIFIED
 SIZE C
 SCALE -
 REV AE

DRAWING NO. 8750W-2051


DUST ENVIRONMENT - EPL Dc COIL AND ELECTRODE CIRCUIT WIRING

MODEL 8750WD WITH NON-INTRINSICALLY SAFE ELECTRODE CIRCUIT

FOR USE WITH SAFETY APPROVAL OPTION ZC

COMPONENT OR COMBINATION COIL/ELECTRODE CABLE ALLOWED.
SEE INSTALLATION WIRING DRAWING 08732-1504 FOR NON-INTRINSICALLY SAFE CABLING
(FOR PROCESS TEMPERATURE LIMITS SEE TABLE 2)

OPTIONAL DIVIDER SHOWN




8750WDMR/W FLOWTUBE
REMOTE JUNCTION BOX

NON-INTRINSICALLY SAFE COIL CIRCUIT
INSTALL USING EPL Dc WIRING
METHODS APPROPRIATE TO THE AREA DEVICE
IS INSTALLED IN

FOR USE WITH NON-FLAMMABLE PROCESS ONLY.
INSTALL ELECTRODE CIRCUIT AS NON-INTRINSICALLY SAFE
USING EPL Dc WIRING METHODS APPROPRIATE
TO THE AREA DEVICE IS INSTALLED IN.

REMOTE MOUNT FLOWTUBE AND TRANSMITTER LAYOUT	
TERMINAL	LABEL
NON-INTRINSICALLY SAFE ELECTRODE CIRCUIT	
19	ELECTRODE +
18	ELECTRODE -
17	ELECTRODE REFERENCE (SE)
NON-INTRINSICALLY SAFE COIL CIRCUIT	
1	COIL +
2	COIL -
3	COIL SHIELD (SC)

OPTIONAL DIVIDER SHOWN




8750WDMR TRANSMITTER
REMOTE JUNCTION BOX

MODEL 8750WD WITH NON-INTRINSICALLY SAFE ELECTRODE CIRCUIT

FOR USE WITH SAFETY APPROVAL OPTION ZC

COMPONENT OR COMBINATION COIL/ELECTRODE CABLE ALLOWED.
SEE INSTALLATION WIRING DRAWING 08712-1504 FOR NON-INTRINSICALLY SAFE CABLING
(FOR PROCESS TEMPERATURE LIMITS SEE TABLE 2)

OPTIONAL DIVIDER SHOWN




8750WDMR/W FLOWTUBE
REMOTE JUNCTION BOX

NON-INTRINSICALLY SAFE COIL CIRCUIT
INSTALL USING EPL Dc WIRING
METHODS APPROPRIATE TO THE AREA
DEVICE IS INSTALLED IN

FOR USE WITH NON-FLAMMABLE PROCESS ONLY.
INSTALL ELECTRODE CIRCUIT AS NON-INTRINSICALLY SAFE
USING EPL Dc WIRING METHODS APPROPRIATE
TO THE AREA DEVICE IS INSTALLED IN.

REMOTE MOUNT FLOWTUBE AND TRANSMITTER LAYOUT	
TERMINAL	LABEL
NON-INTRINSICALLY SAFE ELECTRODE CIRCUIT	
19	ELECTRODE +
18	ELECTRODE -
17	ELECTRODE REFERENCE (SE)
NON-INTRINSICALLY SAFE COIL CIRCUIT	
1	COIL +
2	COIL -
3	COIL SHIELD (SC)

OPTIONAL
DIVIDERS
SHOWN



8750WDMW TRANSMITTER
(LOWER COVER AND SAFETY COVER ARE NOT SHOWN)

8750W-2051
DRAWING NO.

CONFIDENTIAL AND PROPRIETARY
INFORMATION IS CONTAINED HEREIN
AND MUST BE HANDLED ACCORDINGLY.

SURFACE FINISH UNLESS
OTHERWISE SPECIFIED

125°
3RD ANGLE

SIZE C

SCALE -

REV AE

UNLESS OTHERWISE SPECIFIED
DIMENSIONS IN INCHES (mm). REMOVE
ALL BURRS AND SHARP EDGES.

-DEC TOLERANCES-
X ± .1 [2.5]
.XX ± .02 [0.5]
.XXX ± .010 [0.25]
FRACTIONS ANGLES
± 1/32 ± 2°

EMERSON

ROSEMOUNT

INSTALLATION DRAWING 8750W,
CSA CANADIAN AND USA ZONE

DR. J. LAGE 9/16/15 DRAWING NO. 8750W-2051

APPD. M. MAYER 9/16/15


DO NOT SCALE PRINT

CAD MAINTAINED. (PROJ)


PRODUCT CODE

SHEET 8 OF 11

GAS AND DUST ENVIRONMENT - OUTPUT WIRING



8750WD MODEL CODE BREAKDOWN Δ 3



WHEN CONNECTED IN ACCORDANCE WITH THIS DOCUMENT, THE ROSEMOUNT MODEL 8750WD SYSTEM IS APPROVED AS

SAFETY APPROVAL OPTION CODE	RATINGS
ZC	Ex ec [ic Gc] TYPE 'e' AND Ex na [ic Gc] TYPE 'n' WITH INTRINSICALLY SAFE ELECTRODE CONNECTIONS - DC POWER ONLY
ZC WITH OUTPUT CODE 'F' OR 'P'	Ex ec [ic Gc] TYPE 'e' AND Ex na [ic Gc] TYPE 'n' WITH INTRINSICALLY SAFE ELECTRODE CONNECTIONS AND INTRINSICALLY SAFE OUTPUTS - DC POWER ONLY
ZC	Ex tc IIIC PROTECTION BY ENCLOSURES
ZC WITH OUTPUT CODE 'F' OR 'P'	Ex tc IIIC PROTECTION BY ENCLOSURES WITH INTRINSICALLY SAFE OUTPUTS

4-20mA ANALOG: INTERNALLY POWERED (ACTIVE): OUTPUTS UP TO 25mA, 24 VDC MODBUS: INTERNALLY POWERED (ACTIVE): OUTPUTS UP TO 100mA, 3.3VDC FIELDBUS OR PROFIBUS: EXTERNALLY POWERED - INTRINSICALLY SAFE (PASSIVE): INPUT U_i = 30 VDC	Δ 7
4-20mA ANALOG OR DIGITAL OUTPUTS	Δ 7
PULSE OUTPUT INTERNALLY POWERED (ACTIVE): OUTPUTS UP TO 12VDC, 12.1mA EXTERNALLY POWERED - INTRINSICALLY SAFE (PASSIVE) INPUT U_i = 28VDC (FIELDBUS AND PROFIBUS ONLY)	Δ 7
AC INPUT POWER 90-250 VAC RMS, 50/60Hz, 40VA DC INPUT POWER 12-42 VDC, 15W	Δ 2 Δ 7

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.

UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.

-DEC TOLERANCES-

X	± .1	[2.5]
.XX	± .02	[0.5]
.XXX	± .010	[0.25]
FRACTIONS	± 1/32	ANGLES ± 2°

EMERSON
ROSEMOUNT

TITLE
INSTALLATION DRAWING 8750W,
CSA CANADIAN AND USA ZONE

DR. J. LAGE 9/16/15 DRAWING NO. 8750W-2051
APPD. M. MAYER 9/16/15


DO NOT SCALE PRINT | CAD MAINTAINED: (PROE) | PRODUCT CODE | SHEET 9 OF 11

8750W-2051
DRAWING NO.

REVISION	SCALE	SIZE	3RD ANGLE	REV
AE	1:1	C	Δ 125	AE

GAS AND DUST ENVIRONMENT - INTRINSICALLY SAFE ENTITY CONCEPTS

8750WDMT/R ENTITY CONCEPT FOR INTRINSICALLY SAFE OUTPUTS



DEFINITIONS:


- U_i = MAXIMUM INPUT VOLTAGE
- i_i = MAXIMUM INPUT CURRENT
- C_i = MAXIMUM INTERNAL CAPACITANCE
- L_i = MAXIMUM INTERNAL INDUCTANCE
- P_i = MAXIMUM INPUT POWER
- U_o = OPEN CIRCUIT VOLTAGE OF THE BARRIER
- I_o = SHORT CIRCUIT CURRENT OF THE BARRIER
- C_o = MAXIMUM ALLOWED CAPACITANCE
- L_o = MAXIMUM ALLOWED INDUCTANCE
- P_o = MAXIMUM OUTPUT POWER

THE ENTITY CONCEPT ALLOWS INTERCONNECTION OF ASSOCIATED APPARATUS AND INTRINSICALLY SAFE APPARATUS WHEN THE FOLLOWING IS TRUE:
 $U_o \leq U_i$, $I_o \leq I_i$, $P_o \leq P_i$, $C_o \geq C_i + C_{cable}$, $L_o \geq L_i + L_{cable}$

ASSOCIATED APPARATUS MUST BE CERTIFIED, AND FOLLOW MANUFACTURER'S INSTALLATION DRAWINGS. TO MAINTAIN THE INTRINSICALLY SAFE OUTPUT THE TRANSMITTER MUST BE CONNECTED TO A CERTIFIED BARRIER THAT SATISFIES THE FOLLOWING CONDITIONS.

APPROVED WITH INTRINSICALLY SAFE CONNECTIONS FOR CLASS I, DIVISION 1, GROUPS ABCD; CLASS II AND III, DIVISION 1, GROUPS EFG.

8750WDMW ENTITY CONCEPT FOR INTRINSICALLY SAFE OUTPUTS



FOUNDATION FIELDBUS AND PROFIBUS DIGITAL OUTPUT

ENTITY PARAMETERS

- U_i = 30V
- I_i = 380mA
- C_i = 924pF
- L_i = 0.0uH

BARRIER PARAMETERS

- U_o MUST BE LESS THAN OR EQUAL TO 30V
- I_o MUST BE LESS THAN OR EQUAL TO 380mA
- C_o MUST BE GREATER THAN THE SUM OF C_i+C_{cable}
- L_o MUST BE GREATER THAN THE SUM OF L_i+L_{cable}

PULSE OUTPUT

ENTITY PARAMETERS

- U_i = 28V
- I_i = 100mA
- C_i = 4.5nF
- L_i = 0.0uH
- P_i = 1.0W

BARRIER PARAMETERS

- U_o MUST BE LESS THAN OR EQUAL TO 28V
- I_o MUST BE LESS THAN OR EQUAL TO 100mA
- C_o MUST BE GREATER THAN THE SUM OF C_i+C_{cable}
- L_o MUST BE GREATER THAN THE SUM OF L_i+L_{cable}
- P_o MUST BE LESS THAN OR EQUAL TO 1.0 WATTS

AC INPUT POWER 90-250 VAC RMS, 50/60Hz
 DC INPUT POWER 12-42 VDC
 DC LOW POWER 12-30 VDC

U_m = 250V

CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.	SURFACE FINISH UNLESS OTHERWISE SPECIFIED	12/5	3RD ANGLE	SCALE	REV
UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.	X ± .1 [2.5]	.XX ± .02 [0.5]	.XXX ± .010 [0.25]	FRACTIONS ± 1/32	ANGLES ± 2°
ROSEMOUNT					
TITLE INSTALLATION DRAWING 8750W, CSA CANADIAN AND USA ZONE					
DR. J. LAGE	9/16/15	DRAWING NO.	8750W-2051		
APPD. M. MAYER	9/16/15	DOC TYPE	SHEET 10 OF 11		
DO NOT SCALE PRINT CAD MAINTAINED. (PROE) PRODUCT CODE					

GAS AND DUST ENVIRONMENT - FISCO CONCEPT

FISCO CONCEPT

THE FISCO CONCEPT ALLOWS INTERCONNECTION OF INTRINSICALLY SAFE APPARATUS TO ASSOCIATED APPARATUS NOT SPECIALLY EXAMINED IN SUCH COMBINATION. THE CRITERIA FOR INTERCONNECTION IS THAT THE VOLTAGE (V_{max}), THE CURRENT (I_{max}), AND THE POWER (P_{max}) WHICH AN INTRINSICALLY SAFE APPARATUS CAN RECEIVE AND REMAIN INTRINSICALLY SAFE CONSIDERING FAULTS, MUST BE EQUAL OR GREATER THAN VOLTAGE (V_{oc}), AND CURRENT (I_{sc}) WHICH CAN BE DELIVERED BY THE ASSOCIATED APPARATUS, CONSIDERING FAULTS AND APPLICABLE FACTORS. IN ADDITION, THE MAXIMUM UNPROTECTED CAPACITANCE (C_i) AND THE INDUCTANCE (L_i) OF EACH APPARATUS (OTHER THAN THE TERMINATION) CONNECTED TO THE FIELDBUS MUST BE LESS THAN OR EQUAL TO 5 nF AND 10 μ H RESPECTIVELY.

IN EACH SEGMENT ONLY ONE ACTIVE DEVICE, NORMALLY THE ASSOCIATED APPARATUS, IS ALLOWED TO PROVIDE THE NECESSARY ENERGY FOR THE FIELDBUS SYSTEM. THE VOLTAGE (V_{oc}) OF THE ASSOCIATED APPARATUS IS LIMITED TO A RANGE OF 14 TO 17.5 VDC. ALL OTHER EQUIPMENT CONNECTED TO THE BUS CABLE HAS TO BE PASSIVE, MEANING THAT THEY ARE NOT ALLOWED TO PROVIDE ENERGY TO THE SYSTEM, EXCEPT A LEAKAGE CURRENT OF 50 μ A FOR EACH CONNECTED DEVICE. SEPARATELY POWERED EQUIPMENT NEEDS GALVANIC ISOLATION TO ASSURE THAT THE INTRINSICALLY SAFE FIELDBUS CIRCUIT REMAINS PASSIVE.

THE CABLE USED TO INTERCONNECT DEVICES NEEDS TO HAVE THE PARAMETERS IN THE FOLLOWING RANGE:

- Loop Resistance R_c : 15.....150 Ohm/km
- Inductance per unit length L_c : 0.4.....1 mH/km
- Capacitance per unit length C_c : 45.....200 nF
- Length of trunk cable: less than or equal to 1000m
- Length of spur cable: less than or equal to 60m

AT EACH END OF THE TRUNK CABLE AN APPROVED INFALLIBLE LINE TERMINATION WITH THE FOLLOWING PARAMETERS IS SUITABLE:

$$R = 90.....102 \text{ Ohm} \quad C = 0.....2.2 \mu\text{f}$$



ONE OF THE ALLOWED TERMINATIONS MIGHT ALREADY BE INTEGRATED IN THE ASSOCIATED APPARATUS. THE NUMBER OF PASSIVE APPARATUS CONNECTED TO THE BUS SEGMENT IS NOT LIMITED TO I.S. REASONS. IF THE ABOVE RULES ARE RESPECTED, UP TO A TOTAL LENGTH OF 1000 m (SUM OF TRUNK AND ALL SPUR CABLES) OF CABLE IS PERMITTED. THE INDUCTANCE AND THE CAPACITANCE OF THE CABLE WILL NOT IMPAIR THE INTRINSIC SAFETY OF THE INSTALLATION.

ENTITY PARAMETER

- $U_i = 30V$
- $I_i = 380 \text{ mA}$
- $C_i = 924 \text{ pF}$
- $L_i = 0.0 \mu\text{H}$
- $P_i = 5.32 \text{ W}$

BARRIER PARAMETERS

- U_o MUST BE LESS THAN OR EQUAL TO 30V
- I_o MUST BE LESS THAN OR EQUAL TO 380 mA
- C_o MUST BE GREATER THAN THE SUM OF $C_i + C_{cable}$
- L_o MUST BE GREATER THAN THE SUM OF $L_i + L_{cable}$



CONFIDENTIAL AND PROPRIETARY INFORMATION IS CONTAINED HEREIN AND MUST BE HANDLED ACCORDINGLY.	SURFACE FINISH UNLESS OTHERWISE SPECIFIED	125°	3RD ANGLE	SIZE	C	SCALE	AE	REV	AE
	UNLESS OTHERWISE SPECIFIED DIMENSIONS IN INCHES (mm). REMOVE ALL BURRS AND SHARP EDGES.								
	EMERSON								
	ROSEMOUNT								
	TITLE INSTALLATION DRAWING 8750W, CSA CANADIAN AND USA ZONE								
	DR.	J. LAGE	9/16/15	DRAWING NO.	8750W-2051				
	APPD.	M. MAYER	9/16/15	DOC TYPE	SHEET 11 OF 11				



For more information: www.emerson.com

©2025 Emerson. All rights reserved.
Emerson Terms and Conditions of Sale are available upon request. The Emerson logo is a trademark and service mark of Emerson Electric Co. Rosemount is a mark of one of the Emerson family of companies. All other marks are the property of their respective owners.